



Safety SOP

Pipe Testing



Review Detailed Test Plan

- ❖ Verify the hazards associated with the pressure test –
 - ❑ **Hydrostatic/Pneumatic**
 - Understand the test and know your specifications
 - Test must be sufficient for the DESIGN pressure ranges
 - ❑ **Test Pressures**
 - Ensure pipe, valves, fittings, etc. are rated accordingly
 - ❑ **Temporary fittings, manifolds, hoses, PRVs, gauges, etc.**
 - TSCD devices must be approved and stamped by engineer (e.g., test tree)
 - Verify calibration and are installed according to the test plan
 - Rated higher than the maximum test pressure, per project specifications
 - Inspected prior to each test
 - ❑ **Barricades/Exclusion Zones**
 - Prohibit non-essential and unauthorized personnel
 - Verify barricade size is appropriate for the test (pneumatic versus hydrostatic)
 - ❑ **SIMOPS**
 - Communicate the test location and hazards prior to execution
 - Establish communication protocol prior to test initiation
 - ❑ **Pressure release/bleed down procedure**
 - Know what's being released (e.g., nitrogen, air)
 - Follow the discharge plan (e.g., ditch, tank, ground)

What Could Go Wrong?

- | | |
|--|--|
| <ul style="list-style-type: none">❖ Temporary device/fitting failure<ul style="list-style-type: none">▪ Incorrect sizes/ratings▪ Over pressurization▪ Plugs vs Welded Caps❖ Incomplete test boundaries<ul style="list-style-type: none">▪ Media leaks▪ Uncontrolled discharge❖ Improper planning<ul style="list-style-type: none">▪ Incorrect test pressure per design▪ Repair of leaks under pressure | <ul style="list-style-type: none">✓ How do we mitigate?...<ul style="list-style-type: none">▪ ASK Questions▪ Field Engineer, Superintendent, and/or FLS verification▪ Know your discharge plan▪ Verify approval from proper authorities prior to execution (i.e., QC signatures)▪ QC Documentation – Eliminate Re-work |
|--|--|